

# STORAGE GUIDELINES CHECK LIST

Place a check mark in the appropriate box regarding the issues listed & total at end of form

YES	NO
-----	----

## FRONT ENTRY

3'-0" CLEARANCE IN FRONT OF DOOR

--	--

## DINING ROOM

CLEAN AND SANITARY PLACE TO EAT MEALS  
FLOORS CLEAN & SANITARY


## KITCHEN

CLEAN AND SANITARY APPLIANCES  
COUNTERS AND FOOD PREP AREA CLEAN & SANITARY  
FLOORING CLEAN AND SANITARY  
SINK IN WORKING ORDER, NO LEAKS DRAINS PROPERLY  
REFRIGERATOR WORKING PROPERLY


## LIVING ROOM

3'-0" CLEARANCE INFRONT OF DOORS AND WINDOWS  
FLOORING CLEAN AND SANITARY


## BEDROOM #1 LOCATION

3'-0" CLEARANCE IN FRONT OF WINDOWS & DOORS  
STORAGE LIMITED TO CABINETS, DRESSERS & CLOSETS  
FLOOR FREE OF CLOTHING AND MISC. ITEMS  
WINDOWS WORKING PROPERLY


## BEDROOM #2 LOCATION

3'-0" CLEARANCE IN FRONT OF WINDOWS & DOORS  
STORAGE LIMITED TO CABINETS, DRESSERS & CLOSETS  
FLOOR FREE OF CLOTHING AND MISC. ITEMS  
WINDOWS WORKING PROPERLY


## BEDROOM #3 LOCATION

3'-0" CLEARANCE IN FRONT OF WINDOWS & DOORS  
STORAGE LIMITED TO CABINETS, DRESSERS & CLOSETS  
FLOOR FREE OF CLOTHING AND MISC. ITEMS  
WINDOWS WORKING PROPERLY


## BEDROOM #4 LOCATION

3'-0" CLEARANCE IN FRONT OF WINDOWS & DOORS  
STORAGE LIMITED TO CABINETS, DRESSERS & CLOSETS  
FLOOR FREE OF CLOTHING AND MISC. ITEMS  
WINDOWS WORKING PROPERLY


**BATHROOMS**

ALL FIXTURES IN A CLEAN & SANITARY CONDITION  
TOILET WORKING PROPERLY  
SINK/TUB/SHOWER WORKING PROPERLY NO LEAKS  
FLOORING CLEAN AND SANITARY  
BATHFAN WORKING PROPERLY


**HALLWAYS, STAIR CASES & LANDINGS**

ALL HALLWAYS FREE OF STORAGE  
ALL STAIRCASES FREE OF STORAGE  
ALL LANDINGS FREE OF STORAGE


**FAMILY ROOM**

3'-0" CLEARANCE INFRONT OF DOORS AND WINDOWS  
FLOORING CLEAN AND SANITARY


**UTILITY ROOM**

3'-0" CLEARANCE AROUND FURNACE  
3'-0" CLEARANCE AROUND WATER HEATER  
3'-0" CLEARANCE IN FRONT OF ELECTRIC PANEL  
METAL DRYER VENTING ENTACT AND FLEXIBLE METAL NOT  
OVER 6'-0". PLASTIC VENTING IS NOT CODE APPROVED


**SMOKE DETECTORS**

SMOKE DETECTOR IN EACH BEDROOM  
SMOKE DETECTOR LOCATED ON EACH LEVEL IN  
COMMON AREA


**CARBON MONOXIDE DETECTORS**

CARBON MONOXIDE DETECTOR LOCATED  
WITHIN 10'-0" OF ALL SLEEPING ROOMS.

--	--

**TOTAL OF CHECKED ITEMS**

--	--

If you have more than 4 items checked "no" you may have some dangerous storage issues. Please contact our office for more information at 763-767-6420 or ldrabczak@coonrapidsmn.gov